



The Institute of Co-operative Management for Agriculture & Rural Development
(ICMARD - Training Institute of The WBSCARD Bank Ltd.)

Block-14/2, C.I.T Scheme-VIII (M), Ultadanga, Kolkata-700067.

Ph-033-23565522 (Principal) / 23566522 (EPBX)

FAX : 033-23563633

Email : icmard.kol@gmail.com



Memo No. 2137/ICMARD/441

Date : 11/03/2021.

NOTICE INVITING QUOTATION

Sealed Quotations are invited from the Government enlisted Contractor or authorised / bonafide outsiders/agencies having requisite experience & adequate skill in the field of installation of Jockey Pump in respect to the Fire Protection System related with the Fire Hydrant System. The Sealed Quotations are invited for the under mentioned works as per Technical Specifications & Schedule/Scope of Work as detailed in the Annexure - enclosed herewith and also as per Terms & Conditions appended below :-

- A) **Name of the Work** : Supply, Installation, Testing and Commissioning of a new electrical motor driven automatic pressurisation (JOCKEY) pumping set suitable for automatic operation and complete in all respect with labour, Piping and other relevant / requisite accessories/ allied fittings / fixtures as detailed/specified in the enclosed Schedule/ Scope of Works (Annexure-) which is to be connected/ synchronized with the existing Fire Panel & Pumping system for Fire Protection System / Fire Hydrant System .
- B) **Place of Work** : In the existing Fire Pump House of "Institute of Co-Op Management for Agriculture & Rural Dev. (ICMARD) Building of The West Bengal State Co-operative Agriculture & Rural Dev. Bank Ltd. located at 14/2, CIT Scheme VIII(M), Ultadanga, Kolkata-700067".

Broad Terms & Conditions and necessary Technical Specifications and other details as specified in the Annexure - (Schedule of Works) :

- (01). The Quoted rates should be inclusive of prevailing GST/Taxes etc. and other incidental charges and transportation charges.
- (02). The rate should be quoted in figures as well as words.
- (03). The Scope/Schedule of work comprises the details enclosed herewith.
- (05). The Quotations must be valid for a period of at least six months from the last date of submission.
- (06). Tools and tackles for the work shall be arranged by the contractor at his own cost.
- (07). The authority of the Institute reserves the right to accept and or reject any or all the Quotations without assigning any reason thereof and also the authority is not bound to accept the lowest rate.
- (08). The Quotation in Letter Head, complete in all respect, must reach to the Principal, ICMARD, under Sealed **Cover latest by 23 March, 2021.**
- (09). The Quotations must furnish the following documents with the Quotations :-
 - a) Copies of applicable GST/PAN/TAN as per prevailing Rules and payment on this score will be deposited with the authority concerned.
 - b) Experience Certificates / Credentials with respect to the captioned works.
- (10). The payment will be released on completion of the work to the satisfaction of the authority as to be demonstrated and on submission of final bill in duplicate.
- (11). 10% of the Final Bill amount shall be deducted at source as Security Deposit and the amount be retained by the Institute for at least 6(Six) months which will accrue no Interest.

Contd... P/2

H.O.- The WBSCARD Bank Ltd.

Block-14/2, C.I.T Scheme-VIII (M), Ultadanga, Kolkata-700067.

Ph-033-2356 -0028 / 2356-0065 Email : wbscardb@gmail.com



The Institute of Co-operative Management for Agriculture & Rural Development
(ICMARD - Training Institute of The WBSCARD Bank Ltd.)
Block-14/2, C.I.T Scheme-VIII (M), Ultadanga, Kolkata-700067.
Ph-033-23565522 (Principal) / 23566522 (EPBX)
FAX : 033-23563633 Email : icmard.kol@gmail.com

(page-2)

- (12). Time for Completion of the whole work will be within **04(four) weeks** from the date of receipt of the work order.
- (13). The Sealed Cover of Quotation shall be superscripted as “ **The Quotation for Supply, Installation, Testing & Commissioning of a Jockey Pump Set** ”
- (14). The Quotations will be liable for rejection in case of violation of the above stipulated Terms and Conditions.
- (15). The warrenty Certificate of the Jokey Pump Set for a period of at least 01 year from the date of handover to be provide.

TECHNICAL SPECIFICATIONS of the whole work :-

JOCKEY PUMP – Providing, fitting & fixing of a new electrical motor driven automatic pressurisation (jockey) pumping set suitable for automatic operation and complete in all respect with all labour, tools & plants, transportation, taxes leview etc. Horizontally mounted, centrifugal tupe single stage jockey pump having cast iron body, bronze impeller carbon steel shaft and capable of delivering 180 LPM against a total head of 80 M and complete with all accessoriosries for successful operation & testing of the pumping system as per the guidelines / nosrms of WBSES. Suitable capacity squirrel cage induction motor T.E.F.V type. The motor shall be suitable for synchronous speed of 3000 RPM confirming to IS:325 & for 415 volts $\pm 10\%$, 3 phase, 50Hz A.C. supply for the above fire pump to couple with flexible coupling as per relevant Indian Stanard & Specifications. Common base plate for mounting pump and motor, fabsricated from suitable M.S.channel including pin bush type coupling as per manufacturer’s recommendation. The Pump motor set to be installed as per manufacturer’s standard with 4 nos heavy duty anti-vibration pads (Cushy foot) including necessary new pipe, fittings, painting & reconnection of power/control cable, as srequired to complete the job

The Pump shall be of horizontal centrifugal type and designed for continuous operation at its best efficiency point. The pump shall have continuously rising head characteristic from operating point towards shut-off, generally complying the regulation. The drive unit of the Pump shall be suitably rated, so that the same can take the load of full open condition. The Pump set along with its drive unit shall run smoothly without undue noise and vibration. Parts of Pump like impeller, shaft sleeve, wearing ring etc. shall be of non-corrosive metal.


PRINCIPAL
ICMARD

Memo. No. 2137/ICMARD/ 441 (3)

Date : 11/03/2021.

Copy forwarded for information and necessary action to -

1. The Managing Director, The WBSCARD Bank Ltd., ICMARD Building, Kolkata - 700067.
2. Display on the Notice Board of The WBSCARD Bank Ltd.
3. Display on the Notice Board of ICMARD, The WBSCARD Bank Ltd.

✓ Miss. S. Mitha, with a request to upload the NFB in the official website of ICMARD


PRINCIPAL
ICMARD

11 / 21

H.O.- The WBSCARD Bank Ltd.
Block-14/2, C.I.T Scheme-VIII (M), Ultadanga, Kolkata-700067.
Ph-033-2356-0028 / 2356-0065 Email : wbscardb@gmail.com



**The Institute of Co-operative Management for Agriculture & Rural Development
(ICMARD - Training Institute of The WBSCARD Bank Ltd.)**

Block-14/2, C.I.T Scheme-VIII (M), Ultadanga, Kolkata-700067.

Ph-033-23565522 (Principal) / 23566522 (EPBX)

FAX : 033-23563633

Email : icmard.kol@gmail.com

ANNEXURE -

(Schedule / Scope of Works)

Ref:- N.I.Q. Memo No. 2137/ICMARD/441 Date : 11/03/2021.

SL. No.	Description/Particulars of the Items of Works	Unit	Qty	Rate (Rs)	Amount (Rs)
1.0	Dismantling of existing Jockey Pump set with power / control cable, suction line, delivery line, suction valve, pressure guage, earthing strip etc. all complete and keep the existing Jockey pump & other materials as per instruction of ICMARD authority.	Job	1		
2.0	Providing, fitting & fixing of a new electrical motor driven automatic pressurisation (jockey) pumping set suitable for automatic operation and complete in all respect with all labour, tools & plants, transportation, taxes leview etc. Horizontally mounted, centrifugal tupe single stage jockey pump having cast iron body, bronze impeller carbon steel shaft and capable of delivering 180 LPM against a total head of 80 M and complete with all accessoriosies for successful operation & testing of the pumping system as per the guidelines / nosrms of WBFES. Suitable capacity squirrel cage induction motor T.E.F.V type. The motor shall be suitable for synchronous speed of 3000 RPM confirming to IS:325 & for 415 volts \pm 10%, 3 phase, 50Hz A.C. supply for the above fire pump to couple with flexible coupling as per relevant Indian Stanard & Specifications. Common base plate for mounting pump and motor, fabstricated from suitable M.S.channel including pin bush type coupling as per manufacturer's recommendation. The Pump motor set to be installed as per manufacturer's standard with 4 nos heavy duty anti-vibration pads (Cushy foot) including necessary new pipe, fittings, painting & reconnection of power/control cable, as required to complete the job with satisfied run. Pump & Motor would be of same make. Make:- For Jockey pump- Kirloskar/K.S.B./Willo	Set complete	1		

Sub Total:- Rs.

Applicable GST @ Rs.

GRAND TOTAL Rs.

(Rupees.

) Only.

I do hereby accept all the stipulated Terms & Conditions as laid in the NIQ vide Memo. No. 2137/ICMARD/441, dated -11/03/2021.

Signature of the Authorised Signatory On behalf of the Agency with Date and Seal

H.O.- The WBSCARD Bank Ltd.

Block-14/2, C.I.T Scheme-VIII (M), Ultadanga, Kolkata-700067.

Ph-033-2356 -0028 / 2356-0065 Email : wbcardb@gmail.com